



Government Of West Bengal
Office Of The Divisional Fire Officer, Nadia
West Bengal Fire & Emergency Services
Azad Hind Sarak, P.O.- Ghurni, P.S.- Kotwali, Pin :- 741103

Memo no.: IND/WB/FES/20192020/60203

Date: 13-12-2023

From:

Divisional Fire Officer, Nadia
West Bengal Fire & Emergency Services

To: JRS PUBLIC SCHOOL

VILL-UTTAR PANCHPOTA, J.L.NO.-120, PLOT NO.-53, 07,06,05, KHATIAN NO.-1048, P.S.-CHAKDAHA, DIST - NADIA, PIN CODE-741222.

Sub: Fire Safety Certificate for an existing construction of G+II storied building under group Educational in the name & style as "JRS PUBLIC SCHOOL" at the premises of: - VILL-UTTAR PANCHPOTA, J.L.NO.-120, PLOT NO.-53, 07,06,05, KHATIAN NO.-1048, P.S.-CHAKDAHA, DIST -NADIA, PIN CODE-741222.

This is in reference to your application no. 0125189231000156 dated 06-12-2023 regarding the Fire Safety Certificate for an existing construction of G+II storied building under group Educational in the name & style as "JRS PUBLIC SCHOOL" at the premises of: - VILL-UTTAR PANCHPOTA, J.L.NO.-120, PLOT NO.-53, 07,06,05, KHATIAN NO.-1048, P.S.-CHAKDAHA, DIST -NADIA, PIN CODE-741222.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

Recommendation:

1. Driveway must be free of any type of obstruction for easy movement of Fire appliances. No parking will be allowed on the Driveway.
2. The interior finish decoration of building shall be made with low flame spread material confirming to the I.S. Specification.
3. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the building shall be strictly maintained.
4. Existing Electrical wiring of the whole building shall have to be carefully checked for any wear and tear them, particularly lines above false ceiling & ducts.
5. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all vulnerable of the Building.
6. The employees and security staff shall be conversant with installed Fire Fighting equipments of the building and to operate in the event of Fire and Testing.
7. Mock Fire Practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number : 0125189231000156.

Page : 1

[Signature]
Manager
JRS Public School
JRS Educational Trust
Chakdaha, Nadia

[Signature]
Manager
JRS Public School
JRS Educational Trust
Chakdaha, Nadia

[Signature]
Principal
JRS PUBLIC SCHOOL
JRS Educational Trust

8. Switch Gear room shall be protected with automatic Co2 or D.C.P. Fire extinction confirming I.S. Specification.
9. A trained Fireman shall be maintained round the clock for safety of the building.
10. First-Aid Fire Fighting system shall be provided as per I.S. Specification.
11. Arrangement shall have to be made for regular checking, testing and maintenance of all the Fire fighting installation in the Building to keep them in perfectly good working condition at all the times.
12. If required the old line shall have to be replace with new lines the cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
13. Periodical flashing of water in the Hose Reel Hose Pipe line shall be made to maintain the efficiency working performance of above mention system.
14. The Fire Safety audit to be conducted a regular interval and to be recorded in the Fire Prevention Maintenance register.
15. Fire License shall have to be obtained for proposed storing and processing L.P.G. and other highly combustible articles.
16. This Fire Safety Certificate is valid for three years and has to be renewed every three year from the date of issue of this letter.

Signature valid

Digitally Signed:
Name: SUSRAT, PUH
Date: 13-Dec-2020 11:33
Reason: Approved
Location: West Bengal

Divisional Fire Officer, Nadia Division, Nadia
West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number : 0125189231000156.

Page : 2

Handwritten signature
Manager

JRS Public School
JRS Educational Trust
Chakdaha, Nadia

Handwritten signature: Beauty Paul
Manager
JRS Public School
JRS Educational Trust
Chakdaha, Nadia

Handwritten signature
Principal
JRS PUBLIC SCHOOL
JRS Educational Trust